

FREE FACILITIES & PROPERTY FIRE & LIFE SAFETY TEMPLATE

Fire and Life Safety Audit Checklist

Use this 60-point checklist to audit exit routes, fire doors, alarm and detection, extinguishers, sprinklers and standpipes, emergency lighting and signs, evacuation planning, responder access, ignition controls, system impairments, corrective actions, and final verification.

Property / building

Audit date

Floor / scope

Auditor / fire-safety owner

Internal Facilities & Property template. Apply the current fire and building code, authority having jurisdiction, insurer requirements, manufacturer instructions, and specialist inspection/testing requirements. Where U.S. OSHA general-industry rules apply, relevant 29 CFR 1910.36, 1910.37, 1910.38, and 1910.157 requirements should be included.

1. Audit scope, occupancy, fire-risk profile, responsibilities, plans, and previous findings

- 1
- Confirm the property, building, floor or zone, audit date, occupancy or operating status, and fire and life-safety audit scope are clearly identified.
- CRITICAL
- FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: Define the exact property scope and occupancy before auditing. Fire and life-safety requirements can vary by building use, height, occupancy, installed systems,...

- 2
- Identify occupied areas, assembly or public areas, sleeping areas where applicable, storage and high-hazard rooms, plant spaces, kitchens, loading zones, and other higher-risk locations included in the audit.
- CRITICAL
- FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: Define the exact property scope and occupancy before auditing. Fire and life-safety requirements can vary by building use, height, occupancy, installed systems,...

- 3
- Verify current emergency plans, evacuation drawings, fire-system records, impairment logs, inspection or service reports, permits, previous audit findings, and open corrective actions are available where applicable.
- CRITICAL
- FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: Define the exact property scope and occupancy before auditing. Fire and life-safety requirements can vary by building use, height, occupancy, installed systems,...

- 4
- Review recent fire alarms, unwanted alarms, incidents, evacuations, extinguisher use, blocked-exit reports, system impairments, fire-door defects, and overdue life-safety work before the walkthrough.
- FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: Define the exact property scope and occupancy before auditing. Fire and life-safety requirements can vary by building use, height, occupancy, installed systems,...

- 5
- Confirm responsibility is defined across property management, facilities, EHS, security, fire wardens, maintenance, contractors, tenants, and emergency-response coordinators.
- CRITICAL
- FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: Define the exact property scope and occupancy before auditing. Fire and life-safety requirements can vary by building use, height, occupancy, installed systems,...

- 6
- Record property, audit date, audit scope, auditor, facilities owner, fire or life-safety owner, management representative, and next planned review date.
- FIRE/LIFE

FINAL STATUS | Enter

FIRE-SAFETY OWNER | Enter

MANAGEMENT APPROVAL | Enter

Execution tip: Define the exact property scope and occupancy before auditing. Fire and life-safety requirements can vary by building use, height, occupancy, installed systems,...

2. Exit routes, exit access, stairs, doors, discharge paths, obstructions, and travel readiness

7 Confirm required exit access, corridors, aisles, stairs, ramps, exit enclosures, exit doors, and final discharge paths are free and unobstructed. **CRITICAL** FIRE/LIFE

Compliant

Needs action

Critical

LIVE PHOTO | Add

Execution tip: Where OSHA general-industry rules apply, exit routes must remain free and unobstructed. Apply the building's current fire and life-safety code requirements for...

8 Check that storage, furniture, waste, carts, equipment, deliveries, decorations, temporary work, construction materials, or tenant items do not reduce or block an exit route. **CRITICAL** FIRE/LIFE

Compliant

Needs action

Critical

LIVE PHOTO | Add

Execution tip: Where OSHA general-industry rules apply, exit routes must remain free and unobstructed. Apply the building's current fire and life-safety code requirements for...

9 Verify exit doors on the audited route can be opened from the egress side as required by the applicable standard and are not locked, chained, obstructed, or disabled in a way that prevents required egress. **CRITICAL** FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: Where OSHA general-industry rules apply, exit routes must remain free and unobstructed. Apply the building's current fire and life-safety code requirements for...

10 Inspect stairs, landings, handrails, guardrails, floor surfaces, ramps, and route lighting for visible defects that could hinder emergency evacuation. **CRITICAL** FIRE/LIFE

Compliant

Needs action

Critical

LIVE PHOTO | Add

Execution tip: Where OSHA general-industry rules apply, exit routes must remain free and unobstructed. Apply the building's current fire and life-safety code requirements for...

11 Confirm the exit discharge leads to a safe exterior area, public way, refuge area, or other approved location and is not blocked by vehicles, gates, construction, storage, or landscaping. **CRITICAL** FIRE/LIFE

Compliant

Needs action

Critical

LIVE PHOTO | Add

Execution tip: Where OSHA general-industry rules apply, exit routes must remain free and unobstructed. Apply the building's current fire and life-safety code requirements for...

12 Escalate any blocked, locked, damaged, or unusable required exit route immediately and apply approved interim controls until the route is restored. **CRITICAL** FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: Where OSHA general-industry rules apply, exit routes must remain free and unobstructed. Apply the building's current fire and life-safety code requirements for...

3. Fire doors, smoke-control doors, exit enclosures, compartmentation clues, and penetration condition

13

Inspect fire doors and smoke-control doors for visible damage, missing components, holes, broken glazing, damaged seals, or other conditions that may affect intended performance.

CRITICAL

FIRE/LIFE

Compliant

Needs action

Critical

LIVE PHOTO | Add

Execution tip: Fire and smoke doors are emergency safeguards, not ordinary doors. Do not permit wedges, storage, damaged closers, or unauthorized penetrations to compromise...

14

Confirm applicable self-closing or automatic-closing fire doors are not wedged, tied, blocked, or otherwise prevented from closing as intended.

CRITICAL

FIRE/LIFE

Compliant

Needs action

Critical

LIVE PHOTO | Add

Execution tip: Fire and smoke doors are emergency safeguards, not ordinary doors. Do not permit wedges, storage, damaged closers, or unauthorized penetrations to compromise...

15

Check door closers, hinges, latches, coordinators, hold-open devices, frames, thresholds, and visible hardware for secure and serviceable condition.

CRITICAL

FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: Fire and smoke doors are emergency safeguards, not ordinary doors. Do not permit wedges, storage, damaged closers, or unauthorized penetrations to compromise...

16

Inspect exit enclosures, fire-resistance separations, riser rooms, electrical rooms, service shafts, and visible wall or ceiling penetrations for obvious unsealed openings or unauthorized alterations.

CRITICAL

FIRE/LIFE

Compliant

Needs action

Critical

LIVE PHOTO | Add

Execution tip: Fire and smoke doors are emergency safeguards, not ordinary doors. Do not permit wedges, storage, damaged closers, or unauthorized penetrations to compromise...

17

Confirm storage and equipment do not obstruct fire doors, exit-enclosure doors, smoke barriers, fire shutters, or other visible compartmentation features.

CRITICAL

FIRE/LIFE

Compliant

Needs action

Critical

LIVE PHOTO | Add

Execution tip: Fire and smoke doors are emergency safeguards, not ordinary doors. Do not permit wedges, storage, damaged closers, or unauthorized penetrations to compromise...

18

Escalate seriously damaged fire doors, doors that will not close, large unprotected openings, or other conditions that may compromise required fire or smoke separation.

CRITICAL

FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: Fire and smoke doors are emergency safeguards, not ordinary doors. Do not permit wedges, storage, damaged closers, or unauthorized penetrations to compromise...

4. Fire alarm, detection, notification, control panels, manual stations, and system status

19

Check the fire-alarm control panel or approved status interface for normal condition and record visible alarm, supervisory, trouble, disabled, or impairment indications.

CRITICAL

FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: A routine audit can verify visible status and accessibility but does not replace required inspection, testing, and maintenance by qualified personnel.

20

Confirm manual fire-alarm stations, call points, pull stations, or equivalent devices are visible, accessible, unobstructed, and not obviously damaged.

CRITICAL

FIRE/LIFE

Compliant

Needs action

Critical

LIVE PHOTO | Add

Execution tip: A routine audit can verify visible status and accessibility but does not replace required inspection, testing, and maintenance by qualified personnel.

21

Inspect visible smoke detectors, heat detectors, beam detectors, notification appliances, speakers, strobes, bells, and related devices for obstruction, damage, paint contamination, or missing components.

CRITICAL

FIRE/LIFE

Compliant

Needs action

Critical

LIVE PHOTO | Add

Execution tip: A routine audit can verify visible status and accessibility but does not replace required inspection, testing, and maintenance by qualified personnel.

22

Verify audible and visible notification coverage concerns, damaged devices, reported inaudible areas, or communication failures are logged for qualified assessment.

CRITICAL

FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: A routine audit can verify visible status and accessibility but does not replace required inspection, testing, and maintenance by qualified personnel.

23

Confirm current fire-alarm inspection, testing, service, fault, isolation, and impairment records are available where required by the property's maintenance programme or authority requirements.

FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: A routine audit can verify visible status and accessibility but does not replace required inspection, testing, and maintenance by qualified personnel.

24

Escalate active alarm-system impairment, disabled critical zones, unresolved trouble conditions, or unavailable notification functions according to the site's approved impairment and emergency process.

CRITICAL

FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: A routine audit can verify visible status and accessibility but does not replace required inspection, testing, and maintenance by qualified personnel.

5. Portable extinguishers, hose equipment, cabinets, locations, access, and maintenance evidence

25

Confirm portable fire extinguishers are in their designated locations, visible or clearly identified, accessible, and not blocked by furniture, storage, displays, or equipment.

CRITICAL

FIRE/LIFE

Compliant

Needs action

Critical

LIVE PHOTO | Add

Execution tip: Where OSHA 1910.157 applies and portable extinguishers are provided for employee use, extinguishers must be visually inspected monthly and receive an annual...

26

Inspect extinguisher body, hose or nozzle, handle, pin or tamper seal, pressure indicator where provided, mounting bracket, cabinet, and signage for obvious damage or abnormal condition.

CRITICAL

FIRE/LIFE

Compliant

Needs action

Critical

LIVE PHOTO | Add

Execution tip: Where OSHA 1910.157 applies and portable extinguishers are provided for employee use, extinguishers must be visually inspected monthly and receive an annual...

27

Check that the extinguisher type and location match the site's approved fire-protection plan or current fire-risk assessment and applicable requirements.

CRITICAL

FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: Where OSHA 1910.157 applies and portable extinguishers are provided for employee use, extinguishers must be visually inspected monthly and receive an annual...

28

Verify monthly visual inspection records are current where OSHA 1910.157 or the site's governing requirement applies.

CRITICAL

FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: Where OSHA 1910.157 applies and portable extinguishers are provided for employee use, extinguishers must be visually inspected monthly and receive an annual...

29

Verify annual maintenance evidence is current where OSHA 1910.157 or the site's governing requirement applies and overdue units are escalated.

CRITICAL

FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: Where OSHA 1910.157 applies and portable extinguishers are provided for employee use, extinguishers must be visually inspected monthly and receive an annual...

30

Escalate missing, discharged, damaged, inaccessible, improperly mounted, or overdue extinguishers according to the property's approved fire-protection process.

CRITICAL

FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: Where OSHA 1910.157 applies and portable extinguishers are provided for employee use, extinguishers must be visually inspected monthly and receive an annual...

6. Sprinklers, standpipes, hose systems, valves, pumps, fire-service connections, and water-based protection

31

Inspect visible sprinkler heads and nearby areas for obstruction, paint contamination, physical damage, missing escutcheons, storage conflicts, or other obvious issues.

CRITICAL

FIRE/LIFE

Compliant

Needs action

Critical

LIVE PHOTO | Add

Execution tip: Do not operate or manipulate fire-protection valves during a routine audit unless authorized. Verify visible access, status, damage, leakage, and current service...

32

Check sprinkler control valves, riser assemblies, alarm valves, supervisory devices, and associated identification for accessibility, obvious leakage, damage, or abnormal status where safely visible.

CRITICAL

FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: Do not operate or manipulate fire-protection valves during a routine audit unless authorized. Verify visible access, status, damage, leakage, and current service...

33

Inspect standpipe or hose cabinets, hose valves, fire department connections, hydrants, and related access points for obstruction, damage, missing caps, poor identification, or unavailable access.

CRITICAL

FIRE/LIFE

Compliant

Needs action

Critical

LIVE PHOTO | Add

Execution tip: Do not operate or manipulate fire-protection valves during a routine audit unless authorized. Verify visible access, status, damage, leakage, and current service...

34

Confirm fire pumps, fire-water tanks, pressure systems, or related fire-protection plant have current service status and no visible alarm, leak, access, or housekeeping issue where applicable.

CRITICAL

FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: Do not operate or manipulate fire-protection valves during a routine audit unless authorized. Verify visible access, status, damage, leakage, and current service...

35

Verify current inspection, testing, maintenance, impairment, and restoration records for water-based fire-protection systems are available where required by the site's programme or authority.

FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: Do not operate or manipulate fire-protection valves during a routine audit unless authorized. Verify visible access, status, damage, leakage, and current service...

36

Escalate closed or impaired valves, unavailable fire-water supply, obstructed fire-service connections, active leakage, or other critical system impairment immediately under the site's impairment process.

CRITICAL

FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: Do not operate or manipulate fire-protection valves during a routine audit unless authorized. Verify visible access, status, damage, leakage, and current service...

7. Exit signs, emergency lighting, backup power, emergency communication, and evacuation information

37

Confirm required exit signs are visible, illuminated or otherwise serviceable as applicable, correctly positioned, and not obscured by decorations, temporary signs, displays, or construction.

CRITICAL

FIRE/LIFE

Compliant

Needs action

Critical

LIVE PHOTO | Add

Execution tip: OSHA 1910.37 requires exit routes to be adequately lighted and exits to be clearly marked in covered workplaces. The property's fire and building code may impose...

38

Check directional exit signage along routes where the direction of travel is not obvious and report missing, misleading, damaged, or obscured signs.

CRITICAL

FIRE/LIFE

Compliant

Needs action

Critical

LIVE PHOTO | Add

Execution tip: OSHA 1910.37 requires exit routes to be adequately lighted and exits to be clearly marked in covered workplaces. The property's fire and building code may impose...

39

Inspect emergency-lighting units, illuminated route markers, stair lighting, and visible backup-lighting fixtures for damage, failed indicators, or reported service issues.

CRITICAL

FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: OSHA 1910.37 requires exit routes to be adequately lighted and exits to be clearly marked in covered workplaces. The property's fire and building code may impose...

40

Verify emergency-lighting or backup-power functional test records are current where required by the site's maintenance programme or applicable authority.

FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: OSHA 1910.37 requires exit routes to be adequately lighted and exits to be clearly marked in covered workplaces. The property's fire and building code may impose...

41

Confirm evacuation maps, emergency instructions, assembly-point information, emergency contacts, and floor or zone identifiers are current, visible, and aligned with the approved emergency plan.

CRITICAL

FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: OSHA 1910.37 requires exit routes to be adequately lighted and exits to be clearly marked in covered workplaces. The property's fire and building code may impose...

42

Escalate dark exit routes, failed required exit signs, unavailable emergency lighting, or inaccurate evacuation information that could hinder safe evacuation.

CRITICAL

FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: OSHA 1910.37 requires exit routes to be adequately lighted and exits to be clearly marked in covered workplaces. The property's fire and building code may impose...

8. Emergency action plan, evacuation roles, drills, assembly areas, accountability, and responder access

43

Verify the current emergency action or evacuation plan is available to affected personnel and reflects the present building layout, occupancy, routes, and emergency arrangements.

CRITICAL

FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: Where OSHA 1910.38 requires an emergency action plan, it must address fire or emergency reporting, evacuation procedures and route assignments, and other...

44

Confirm procedures exist for reporting a fire or other emergency and that emergency contact methods are known and accessible.

CRITICAL

FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: Where OSHA 1910.38 requires an emergency action plan, it must address fire or emergency reporting, evacuation procedures and route assignments, and other...

45

Verify evacuation roles such as wardens, floor marshals, sweepers, first-aid responders, security, or incident coordinators are assigned and current where used.

FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: Where OSHA 1910.38 requires an emergency action plan, it must address fire or emergency reporting, evacuation procedures and route assignments, and other...

46

Check assembly areas, refuge areas where applicable, accountability processes, visitor or contractor evacuation arrangements, and assistance procedures for people requiring support.

CRITICAL

FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: Where OSHA 1910.38 requires an emergency action plan, it must address fire or emergency reporting, evacuation procedures and route assignments, and other...

47

Review recent drill or evacuation records, observed deficiencies, delayed movement, alarm-recognition issues, accountability gaps, and corrective actions.

FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: Where OSHA 1910.38 requires an emergency action plan, it must address fire or emergency reporting, evacuation procedures and route assignments, and other...

48

Confirm fire-service access routes, emergency gates, key or access arrangements, fire-control rooms, hydrants, fire department connections, and responder entry points are not obstructed.

CRITICAL

FIRE/LIFE

Compliant

Needs action

Critical

LIVE PHOTO | Add

Execution tip: Where OSHA 1910.38 requires an emergency action plan, it must address fire or emergency reporting, evacuation procedures and route assignments, and other...

9. Ignition sources, high-risk rooms, combustible storage, hot work, kitchens, contractors, and impairments

49

Inspect electrical rooms, plant rooms, generator areas, battery or charging areas, kitchens, workshops, storage rooms, waste areas, and other higher-risk spaces for obvious fire hazards.

CRITICAL

FIRE/LIFE

Compliant

Needs action

Critical

LIVE PHOTO | Add

Execution tip: Fire prevention depends on controlling ignition, fuel, and system impairment. Give special attention to electrical rooms, kitchens, hot work, temporary installations,...

50

Confirm combustible materials are not accumulating against heat sources, electrical equipment, fire doors, exit routes, sprinkler controls, or other critical fire-protection features.

CRITICAL

FIRE/LIFE

Compliant

Needs action

Critical

LIVE PHOTO | Add

Execution tip: Fire prevention depends on controlling ignition, fuel, and system impairment. Give special attention to electrical rooms, kitchens, hot work, temporary installations,...

51

Check portable heaters, cooking appliances, charging equipment, extension leads, temporary power, heat-producing equipment, and similar ignition sources for unauthorized or visibly unsafe use.

CRITICAL

FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: Fire prevention depends on controlling ignition, fuel, and system impairment. Give special attention to electrical rooms, kitchens, hot work, temporary installations,...

52

Verify hot-work activities are controlled under the site's permit or authorization process where applicable, with required isolation, fire watch, housekeeping, and post-work checks.

CRITICAL

FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: Fire prevention depends on controlling ignition, fuel, and system impairment. Give special attention to electrical rooms, kitchens, hot work, temporary installations,...

53

Confirm contractors and temporary works do not block exits, disable fire systems without authorization, compromise fire doors, obstruct sprinklers, create uncontrolled combustible loading, or restrict fire-service access.

CRITICAL

FIRE/LIFE

Compliant

Needs action

Critical

LIVE PHOTO | Add

Execution tip: Fire prevention depends on controlling ignition, fuel, and system impairment. Give special attention to electrical rooms, kitchens, hot work, temporary installations,...

54

Review active fire-system impairments, temporary shutdowns, isolated zones, disabled detectors, sprinkler outages, or inaccessible fire equipment and confirm approved compensatory measures and restoration ownership are in place.

CRITICAL

FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: Fire prevention depends on controlling ignition, fuel, and system impairment. Give special attention to electrical rooms, kitchens, hot work, temporary installations,...

10. Audit findings, critical controls, corrective actions, verification, trends, and management sign-off

55

Classify each finding by egress, fire door or compartmentation, alarm or detection, extinguisher, sprinkler or water system, emergency lighting or signage, evacuation planning, ignition control, impairment, or other approved category.

FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: Life-safety findings should remain open until the hazard or impairment is objectively verified as corrected. Repeated findings should trigger system-level...

56

Prioritize findings using life-safety impact, number of occupants exposed, loss of required protection, fire-growth potential, evacuation impact, system impairment, recurrence, and urgency.

CRITICAL

FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: Life-safety findings should remain open until the hazard or impairment is objectively verified as corrected. Repeated findings should trigger system-level...

57

Apply immediate controls such as removing obstructions, restricting access, establishing a fire watch, restoring an exit, isolating an ignition source, or implementing another approved compensatory measure where required.

CRITICAL

FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: Life-safety findings should remain open until the hazard or impairment is objectively verified as corrected. Repeated findings should trigger system-level...

58

Create or link facilities work orders, fire-alarm or sprinkler service calls, extinguisher service, fire-door repairs, electrical actions, contractor corrections, specialist reviews, or authority follow-up with named owners and due dates.

CRITICAL

FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: Life-safety findings should remain open until the hazard or impairment is objectively verified as corrected. Repeated findings should trigger system-level...

59

Verify significant corrective actions through reinspection, live photos, functional testing, service reports, maintenance certificates, impairment-restoration records, or specialist sign-off before closure.

CRITICAL

FIRE/LIFE

Life-safety item	Finding / status	Owner	Evidence	Action
------------------	------------------	-------	----------	--------

Execution tip: Life-safety findings should remain open until the hazard or impairment is objectively verified as corrected. Repeated findings should trigger system-level...

60

Record final fire and life-safety status, critical open impairments, restricted areas, overdue actions, repeat findings, next audit date, auditor, fire or life-safety owner, facilities owner, and management approval.

CRITICAL

FIRE/LIFE

FINAL STATUS | Enter

FIRE-SAFETY OWNER | Enter

MANAGEMENT APPROVAL | Enter

Execution tip: Life-safety findings should remain open until the hazard or impairment is objectively verified as corrected. Repeated findings should trigger system-level...